

WELL RESIDENCIAL

HIGUERÓN

PROMOCIÓN VIVIENDAS
SOUTH RESIDENCE



Realizado por: Sandra Sánchez

WELL PTA


ssanchez@acsos.es
674 24 35 71



Revisado por: Bieito Silva

Arquitecto y Well AP

bsilva@acsos.es
677 653320



Datos del proyecto

Tipo de trabajo: WELL RESIDENCIAL
Fecha de realización: 15/04/2026
Nº de referencia: 251257

ÍNDICE

1 INTRODUCCIÓN	4
2. AGUA	5
1.1 R-W02.2. CUMPLIR CON LOS UMBRALES DE CONTAMINANTES ORGÁNICOS.	5
1.2 RESULTADOS DE LAS MEDICIONES.	6

1 INTRODUCCIÓN

Este informe tiene como objetivo describir los trabajos y resultados obtenidos durante las mediciones realizadas para el pre-test de WELL RESIDENCIAL, en la promoción de viviendas situada en, Av. 8 de Marzo, Fuengirola, Málaga.

Las mediciones se realizaron los días 21 de octubre de 2025 y 18 de marzo de 2026.

Se volvió a hacer una medición en la vivienda Brick 209 ya que los niveles de plomo eran elevados el 21 de julio de 2026. Los resultados de laboratorio se han incorporado en la página 24.

2. AGUA

1.1 R-W02.2. Cumplir con los umbrales de contaminantes orgánicos.

Cumplir con los siguientes umbrales:

COMPUESTOS QUÍMICOS	CONCENTRACIÓN LÍMITE
Turbidez	≤ 1 NTU
Cloro residual (libre)	≤ 5 ppm
Cobre	$\leq 1,3$ ppm
Plomo	≤ 5 ppb

1.2 Resultados de las mediciones.

PUNTO 1:	LEIRO 219	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,002	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,20	sí
Cloro	≤ 5 ppm	0,05	sí

PUNTO 2:	LEIRO 318	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,004	sí
Plomo	≤ 5 ppb	2	sí
Turbidez	≤ 1 NTU	0,20	sí
Cloro	≤ 5 ppm	0,05	sí

PUNTO 3:	LEIRO 416	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,004	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,20	sí
Cloro	≤ 5 ppm	0,05	sí

PUNTO 4:	LEIRO 514	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,002	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,20	sí
Cloro	≤ 5 ppm	0,05	sí

PUNTO 5:	BIRK 209	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,027	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,20	sí
Cloro	≤ 5 ppm	0,05	sí

PUNTO 6:	BIRK 102	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,017	sí
Plomo	≤ 5 ppb	2	sí
Turbidez	≤ 1 NTU	0,20	sí
Cloro	≤ 5 ppm	0,05	sí

PUNTO 7:	BIRK 504	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,002	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,4	sí
Cloro	≤ 5 ppm	0,07	sí

PUNTO 8:	DARK 602	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,002	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,4	sí
Cloro	≤ 5 ppm	0,036	sí

PUNTO 9:	DARK 403	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,002	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,3	sí
Cloro	≤ 5 ppm	0,01	sí

PUNTO 10:	ALFIL 501	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,003	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,5	sí
Cloro	≤ 5 ppm	0,24	sí

PUNTO 11:	ALFIL 306	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,002	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,6	sí
Cloro	≤ 5 ppm	0,076	sí

PUNTO 12:	ALFIL 201	CONFIGURACIÓN:	GRIFO COCINA
COMPUESTO	VALORES LÍMITE WELL	RESULTADOS DE ANALÍTICAS	¿CUMPLE WELL RESIDENCIAL ?
Cobre	$\leq 1,3$ ppm	0,003	sí
Plomo	≤ 5 ppb	1	sí
Turbidez	≤ 1 NTU	0,6	sí
Cloro	≤ 5 ppm	0,026	sí

ANEXO I: RESULTADOS DE LABORATORIO



Analysis report

GENERAL DATA
REPORT Nº: 4458060
ANALYSIS Nº: 9110587
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 11 AB
TOWN: 28046-Madrid
SAMPLE DENOMINATION: 251257-W01 LEIRO PL 2 VIV 219
SAMPLE DESCRIPTION: Plastic bottle of 500 mL(1), sterile 15 mL container (HNO3)(1), containing drinking water
RECEIPT DATE: 22/10/2025
END DATE: 28/10/2025

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 22/10/2025.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Organoleptics characters				
Turbidity	PE-COR-092	4	< 0.20 ± 19%	UNF
Physical and chemical constituents				
Free Residual Chlorine	PE-COR-009	1.0	< 0.05 ± 17%	mg/L
Total residual chlorine	PE-COR-009		< 0.05 ± 13%	mg/L
Metals				
Copper	PE-COR-023	2	< 0.002 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
SAMPLING DATE: 21/10/2025

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Víctor Beano Cuenca, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 28 October of 2025

Analysis report

GENERAL DATA
REPORT Nº: 4458081
ANALYSIS Nº: 9110588
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 11 AB
TOWN: 28046-Madrid
SAMPLE DENOMINATION: 251257-W02 LEIRO PL 3 VIV 318
SAMPLE DESCRIPTION: Plastic bottle of 500 mL(1), sterile 15 mL container (HNO3)(1), containing drinking water
RECEIPT DATE: 22/10/2025
END DATE 28/10/2025

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 22/10/2025.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Organoleptics characters				
Turbidity	PE-COR-092	4	0.20 ± 19%	UNF
Physical and chemical constituents				
Free Residual Chlorine	PE-COR-009	1.0	< 0.05 ± 17%	mg/L
Total residual chlorine	PE-COR-009		< 0.05 ± 13%	mg/L
Metals				
Copper	PE-COR-023	2	0.004 ± 12%	mg/L
Lead	PE-COR-023	10	2 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
SAMPLING DATE: 21/10/2025

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Víctor Beano Cuenca, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 28 October of 2025

Analysis report

GENERAL DATA
REPORT Nº: 4458891
ANALYSIS Nº: 9110585
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 11 AB
TOWN: 28046-Madrid
SAMPLE DENOMINATION: 251257-W03 APARTA 416 LEIRO
SAMPLE DESCRIPTION: Plastic bottle of 500 mL(1), sterile 15 mL container (HNO3)(1), containing drinking water
RECEIPT DATE: 22/10/2025
END DATE: 28/10/2025

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 22/10/2025.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Organoleptics characters				
Turbidity	PE-COR-092	4	< 0.20 ± 10%	UNF
Physical and chemical constituents				
Free Residual Chlorine	PE-COR-009	1.0	< 0.05 ± 17%	mg/L
Total residual chlorine	PE-COR-009		< 0.05 ± 13%	mg/L
Metals				
Copper	PE-COR-023	2	0.004 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
SAMPLING DATE: 21/10/2025

OBSERVATIONS
This report modifies the report number 4458058, due to name change due to laboratory error.

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Mercedes Berjano Guillán, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 29 October of 2025

Analysis report

GENERAL DATA
REPORT Nº: 4458892
ANALYSIS Nº: 9110588
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 11 AB
TOWN: 28046-Madrid
SAMPLE DENOMINATION: 251257-W04 APARTA 514 LEIRO
SAMPLE DESCRIPTION: Plastic bottle of 500 mL(1), sterile 15 mL container (HNO3)(1), containing drinking water
RECEIPT DATE: 22/10/2025
END DATE: 28/10/2025

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 22/10/2025.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Organoleptics characters				
Turbidity	PE-COR-092	4	< 0.20 ± 19%	UNF
Physical and chemical constituents				
Free Residual Chlorine	PE-COR-009	1.0	< 0.05 ± 17%	mg/L
Total residual chlorine	PE-COR-009		< 0.05 ± 13%	mg/L
Metals				
Copper	PE-COR-023	2	0.002 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
SAMPLING DATE: 21/10/2025

OBSERVATIONS
This report modifies the report number 4458059, due to name change due to laboratory error.

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Mercedes Berjano Guillán, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 29 October of 2025

Analysis report

GENERAL DATA
REPORT Nº: 4458050
ANALYSIS Nº: 9110577
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 11 AB
TOWN: 28046-Madrid
SAMPLE DENOMINATION: 251257-W05 APART 209
SAMPLE DESCRIPTION: Plastic bottle of 500 mL(1), sterile 15 mL container (HNO3)(1), containing drinking water
RECEIPT DATE: 22/10/2025
END DATE 28/10/2025

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 22/10/2025.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Organoleptics characters				
Turbidity	PE-COR-092	4	< 0.20 ± 19%	UNF
Physical and chemical constituents				
Free Residual Chlorine	PE-COR-009	1.0	< 0.05 ± 17%	mg/L
Total residual chlorine	PE-COR-009		< 0.05 ± 13%	mg/L
Metals				
Copper	PE-COR-023	2	0.027 ± 12%	mg/L
Lead	PE-COR-023	10	6 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
SAMPLING DATE: 21/10/2025

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Víctor Beano Cuenca, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 28 October of 2025

Analysis report

GENERAL DATA
REPORT Nº: 4458051
ANALYSIS Nº: 9110578
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 11 AB
TOWN: 28046-Madrid
SAMPLE DENOMINATION: 251257-W06 APRT 102
SAMPLE DESCRIPTION: Plastic bottle of 500 mL(1), sterile 15 mL container (HNO3)(1), containing drinking water
RECEIPT DATE: 22/10/2025
END DATE: 28/10/2025

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 22/10/2025.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Organoleptics characters				
Turbidity	PE-COR-092	4	< 0.20 ± 19%	UNF
Physical and chemical constituents				
Free Residual Chlorine	PE-COR-009	1.0	< 0.05 ± 17%	mg/L
Total residual chlorine	PE-COR-009		< 0.05 ± 13%	mg/L
Metals				
Copper	PE-COR-023	2	0.017 ± 12%	mg/L
Lead	PE-COR-023	10	2 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
SAMPLING DATE: 21/10/2025

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Víctor Beano Cuenca, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 28 October of 2025

Analysis report

GENERAL DATA
REPORT Nº: 4614538
ANALYSIS Nº: 9547077
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 1
TOWN: 28046 - Madrid
SAMPLE DENOMINATION: 251257-W07
SAMPLE DESCRIPTION: Plastic bottle of 50 mL (HNO ₃)(1), containing drinking water
RECEIPT DATE: 20/03/2026
END DATE: 25/03/2026

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 20/03/2026.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Metals				
Copper	PE-COR-023	2	< 0.002 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
VIV BIRM. PISO 504

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Eva Rodríguez Alcocer, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 25 March of 2026

Analysis report

GENERAL DATA
REPORT Nº: 4614539
ANALYSIS Nº: 9547078
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 1
TOWN: 28048 - Madrid
SAMPLE DENOMINATION: 251257-W08
SAMPLE DESCRIPTION: Plastic bottle of 50 mL (HNO ₃)(1), containing drinking water
RECEIPT DATE: 20/03/2026
END DATE 25/03/2026

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 20/03/2026.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Metals				
Copper	PE-COR-023	2	< 0.002 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
VIV.DARK PISO 602

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Eva Rodríguez Alcoer, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 25 March of 2026

Analysis report

GENERAL DATA
REPORT Nº: 4814540
ANALYSIS Nº: 9547079
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 1
TOWN: 28046 - Madrid
SAMPLE DENOMINATION: 251257-W09
SAMPLE DESCRIPTION: Plastic bottle of 50 mL (HNO ₃)(1), containing drinking water
RECEIPT DATE: 20/03/2026
END DATE: 25/03/2026

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 20/03/2026.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Metals				
Copper	PE-COR-023	2	< 0.002 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
VIV DARK PISO 403

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Eva Rodríguez Alcocer, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 25 March of 2026

Analysis report

GENERAL DATA
REPORT Nº: 4614541
ANALYSIS Nº: 9547080
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 1
TOWN: 28046 - Madrid
SAMPLE DENOMINATION: 251257-W10
SAMPLE DESCRIPTION: Plastic bottle of 50 mL (HNO ₃)(1), containing drinking water
RECEIPT DATE: 20/03/2026
END DATE: 25/03/2026

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 20/03/2026.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Metals				
Copper	PE-COR-023	2	0.003 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
VIV.ALFIL PISO 501

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Eva Rodríguez Alcocer, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 25 March of 2026

Analysis report

GENERAL DATA	
REPORT Nº:	4614542
ANALYSIS Nº:	9547081
APPLICANT:	AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS:	Paseo de la Castellana 143 Planta 1
TOWN:	28046 - Madrid
# SAMPLE DENOMINATION:	251257-W11
SAMPLE DESCRIPTION:	Plastic bottle of 50 mL (HNO ₃)(1), containing drinking water
RECEIPT DATE:	20/03/2026
END DATE	25/03/2026

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 20/03/2026.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Metals				
Copper	PE-COR-023	2	< 0.002 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
VIV ALFIL PISO 306

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Eva Rodríguez Alcoer, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 25 March of 2026

Analysis report

GENERAL DATA
REPORT Nº: 4614543
ANALYSIS Nº: 9547082
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L
ADDRESS: Paseo de la Castellana 143 Planta 1
TOWN: 28046 - Madrid
SAMPLE DENOMINATION: 251257-W12
SAMPLE DESCRIPTION: Plastic bottle of 50 mL (HNO ₃)(1), containing drinking water
RECEIPT DATE: 20/03/2026
END DATE: 25/03/2026

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 20/03/2026.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Metals				
Copper	PE-COR-023	2	0.003 ± 12%	mg/L
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
VIV ALFIL PISO 201

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Eva Rodríguez Aloocer, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 25 March of 2026

En la vivienda BRICK 209 se repitieron los análisis de plomo y esto son los resultados:



Analysis report

GENERAL DATA				
REPORT Nº: 4773801				
ANALYSIS Nº: 9364542				
APPLICANT: AMBISALUD CALIDAD AMBIENTAL, S.L				
ADDRESS: Paseo de la Castellana 143 Planta 11 AB				
TOWN: 28046-Madrid				
# SAMPLE DENOMINATION: 251257-W01				
SAMPLE DESCRIPTION: 15 mL container (HNO ₃)(1), containing drinking water				
RECEIPT DATE: 22/07/2026				
END DATE: 3/08/2026				

Analysis performed in LABAQUA, S.A.U. Tests covered by ENAC accreditation nº 109/LE285; C/ Dracma,16-18- Pol. Ind. Las Atalayas 03114 ALICANTE - Tel. +34 965 10 60 70:
Start analysis date 22/07/2026.

PARAMETERS	METHODS	RD 3/2023	RESULTS	UNITS
Metals				
Lead	PE-COR-023	10	< 1 ± 12%	µg/L

INFORMATION SUBMITTED BY THE CLIENT
VIVIENDA BRK 209

The sections indicated with the symbol # correspond to information provided by the client, the laboratory is not responsible for said information, nor is it covered by the scope of accreditation. This report only concerns the sample analyzed as received and may only be partially reproduced with written authorization from the laboratory.

Validated in Labaqua Alicante by Technical Expert: Mercedes Berjano Guillán, Technical Director: Francisco García Andreu.

Electronically signed report in its digital format. Authenticity verifiable using the root certificate from the certifying entity.

Issued in ALICANTE, 3 August of 2026